



THE CORPORATION OF THE TOWNSHIP OF  
LANARK HIGHLANDS

RFT PR-2021-01

Addendum #1

## **PASSIVATION PROCESS**



TO: ALL BIDDERS

**SUBJECT: Addendum #1**

Bidders are instructed to include this addendum along with their bid documents. Failure to include this addendum may result in disqualification from the bidding process.

- 1) When bidding on Bid Form #1 & Bid Form #2 (chart 1) bidders are to include the cost for passivation on the galvanized steel models.
- 2) The passivation process must be conducted after the installation of the condenser. While the arena plant is operating to ensure the arena can open on time.
- 3) The time period for the passivation is 12 weeks.
- 4) Staff have confirmed the existing cinder block stand will support the weight of the new unit.